

**Government of Andhra Pradesh****A.P. State Disaster Response and Fire Services Department****Periodical Renewal Fire Certificate**

From:  
Regional Fire Officer  
Zone-2,Rajahmundry  
Andhra Pradesh.

To:  
The Commissioner, Commissionerate of  
Higher Education, Garudadri KK Towers,  
Sri Lakshmi Narasimha Colony,  
Mangalagiri, Guntur District, Andhra  
Pradesh, PIN - 522503.,

**File No: 31292/NTR/RFO/2026, Date:21/04/2026**

**Occupancy NoC RC Number: 551/RFO/ER/2017**

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **Lakkireddy Balireddy College of Engineering, represented by G.Srinivasa Reddy, Lakkireddy Balireddy College of Engineering, D.No. 10-35A, R.S.No.188/1 & 188/2, Mylavaram, N.T.R District-521230** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
  2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
  3. This Office NOC for Occupancy Rc No. 551/RFO/ER/2017, Dt.24/04/2017
  4. Renewal NOC For Occupancy 551/RFO/ER/2017, Dt.11/04/2025
  5. Online Application for Renewal NOC of G.Srinivasa Reddy, Lakkireddy Balireddy College of Engineering, D.No. 10-35A, R.S.No.188/1 & 188/2, Mylavaram, N.T.R District-521230 - Inspection report called for Regarding.
  6. Online Inspection Report submitted by Officers of this Department on 18-04-2026.

-- x --

The Management of Lakkireddy Balireddy College of Engineering, represented by G.Srinivasa Reddy, Lakkireddy Balireddy College of Engineering, D.No. 10-35A, R.S.No.188/1 & 188/2, Mylavaram, N.T.R District-521230 has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.975000/- vide challan No. 11012318212026, Dated 11/04/2026 at , .

**Admin Building ,Others(Generator, Security, Vastu Building etc)  
,Canteen Block ,Mechanical Engineering Lab-2 ,Mechanical  
Engineering Lab-1 ,Aero Dynamics Block**

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **G.Srinivasa Reddy Lakkireddy Balireddy College of Engineering, D.No. 10-35A, R.S.No.188/1 & 188/2, Mylavaram, N.T.R District-521230**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 11/04/2026 to 10/04/2031.


5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
11012318212026	2026-04-11	975000

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

The Inspection committee consists of DDRFO-NTR & FSI0-Mylavaram has inspected the premisses and offered the remarks as : Recommended : Sir, submitted that the management has obtained Occupancy NOC on 24.04.2017 vide File No.551/RF0/ER/2017 of the Regional Fire Officer, Eastern Region, Vijayawada and renewed on 11.04.2025 vide File No.25873/NTR/MSB/2025 of the Director General, State Disaster Response and Fire Services, A.P., Vijayawada. The inspection committee inspected the existing educational building and tested the firefighting equipment and found in working condition. The inspection committee conducted mock drill and awareness programme and demonstrated the use of firefighting equipment to the staff and students.

  
21/4/26

**"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"****"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"****"సూరక్షిత పాఠశాలలు, సూరక్షిత మైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రత పై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."**

Your Sincerely,

*[Handwritten Signature]*  
21/4/26  
Regional Fire Officer  
Zone-2, Rajahmundry  
Andhra Pradesh.

***In case of emergency, please call 101 or 08659-222229 or 9963724958***

Copy to G.Srinivasa Reddy, Lakkireddy Balireddy College of Engineering, D.No. 10-35A,  
R.S.No.188/1 & 188/2, Mylavaram, N.T.R District-521230.

Copy to Chief Office for Record Purpose

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned