



LAKIREDDY BALI REDDY COLLEGE OF ENGINEERING

(AUTONOMOUS)

Accredited by NAAC with 'A' Grade, ISO 9001:2015 Certified Institution

Approved by AICTE, New Delhi and Affiliated to JNTUK, Kakinada

L.B.Reddy Nagar, Mylavaram-521230, Krishna Dist, Andhra Pradesh, India

DEPARTMENT OF MECHANICAL ENGINEERING

Summary of Events Organized by ISHRAE in A.Y: 2019-20

S. No	Name of the Event	Resource Person	DATE	Number of Students Participated
1.	Webinar conducted in association with ISHRAE Vijayawada sub-chapter on Energy conservation in HVAC systems	Dr.K.V.Narasimha Rao, Professor, Department of Mechanical Engineering, KL University, Guntur.	02-06-2020	51



LAKIREDDY BALI REDDY COLLEGE OF ENGINEERING

(AUTONOMOUS)

Accredited by NAAC & NBA (CSE, IT, ECE, EEE & ME)

Approved by AICTE, New Delhi and Affiliated to JNTUK, Kakinada

L.B.Reddy Nagar, Mylavaram-521230, Krishna Dist, Andhra Pradesh, India

DEPARTMENT OF MECHANICAL ENGINEERING

WEBINAR REPORT ON

ENERGY CONSERVATION IN IN HVAC SYSTEMS

- Event Type : WEBINAR
- Date / Duration : 02-06-2020/ 11:00 am-12:30 pm
- Resource Person : Dr.K.V.Narasimha Rao, Professor, Dept of ME, KLU, Guntur
- Name of Coordinator : Dr.P.Vijaya Kumar
- Target Audience : All ISHRAE Registered students
- Total no of Participants: 51
- Objective of the event : To enhance the knowledge of students in Energy conservation opportunities in HVAC systems.
- Outcome of event : 1) Students learnt about the HVAC systems and energy conservation possibilities in such type of equipment.
- 2) Students got awareness on job opportunities for HVAC engineers.

Description / Report on Event:

A webinar was organized by ISHRAE Student chapter of LBRCE on “**Energy conservation in HVAC systems**” on 02-06-2020. The resource person Dr. K.V.Narasimha Rao, Professor, Department of Mechanical Engineering, KL University, Guntur. The programme was started after the introduction of the guest and programme by the programme chair Ms.Sandeepani Vajje. The session started at 11 AM and continued upto 12.30PM. The source person has given the lecture in a very lucid and easy to understand manner to the participants. He has given examples wherever necessary for making the

students better understand the energy conservation possibilities. He has also given students awareness on the opportunities in the HVAC field locally and globally for this one has equip himself with strong technical knowledge. The attendees were very much satisfied by attending the webinar.

Feedback / Suggestions:

Photographs:

STUDENTS
IN
ISHRAE

ISHRAE
Vijayawada Sub-Chapter

ISHRAE Vijayawada Sub-Chapter
In association with
Lakireddy BaliReddy College of Engineering, Mylavaram
Is conducting a webinar on

Energy Conservation in HVAC systems

SPEAKER



Dr. K V Narasimha Rao
Ph.D (IISc) , F.I.E

Dr K.V. Narasimha Rao is a senior Professional with 27 years of experience in Academic, Consultancy and Industry. He worked for seven years as Research Associate and Fellow in Industrial Energy Group at Tata Energy Research Institute (TERI) and worked as Principal/Director/Dean at various reputed Educational Institutions and has published over 38 scientific papers and numerous technical reports for various National/International Agencies. He specializes in the areas of Energy Auditing, Energy Conservation & Management, Food precooling, Heat Transfer, Refrigeration and Air-conditioning and Renewable Energy Sources

Date: 2nd June, 2020
Time: 11:00 a.m onwards

Registration Details:
<https://attendee.gotowebinar.com/register/5051753860091735311>

Mr. Sk Muneer
President (SY 2020-21)

Mr. P Sobhan Kumar
Secretary (SY 2020-21)

In association with



For more details
K V T Prasad
Student Chair,
Vijayawada Sub-Chapter
7036777736

SPEAKER



Dr. K V Narasimha Rao
Ph.D (IISc) , F.I.E

Dr K.V. Narasimha Rao is a senior Professional with 27 years of experience in Academic, Consultancy and Industry. He worked for seven years as Research Associate and Fellow in Industrial Energy Group at Tata Energy Research Institute (TERI) and worked as Principal/Director/Dean at various reputed Educational Institutions and has published over 38 scientific papers and numerous technical reports for various National/International Agencies. He specializes in the areas of Energy Auditing, Energy Conservation & Management, Food precooling, Heat Transfer, Refrigeration and Air-conditioning and Renewable Energy Sources

Qualifications & Awards

- B. Tech. (Mechanical Engg) from Regional Engg College, Warangal – 1986 (now upgraded as NITW)
- M. S. (Engg) by Research from Indian Institute of Science, Bangalore - 1990 (Thermal Engg)
- Ph. D. from Indian Institute of Science, Bangalore – 1995 (Fruit & Vegetable Precooling-Refrigeration & AC)
- 'National Merit Scholarship' Holder during 1979-85 (Six Years) – Top 100 in SSC/Intermediate
- Winner of "Special Prize" at the 'Mathematics Olympiad' during 1981 @ Senior Level.

Professional Experience

- Teaching & Research – at Vasavi, Hyderabad; IISc, Bangalore & M S R I T, Bangalore – 2 Years
- Industry: Premier Radiators Private Limited, Coimbatore – 1 Year (1994-1995)
- Consultancy & Applied Research – Tata Energy Research Institute, SRC, Bangalore–7 Years [1995-2002]
- Academic & Administration: Sree Vidyanikethan Engineering College, Tirupati; RIT, Yanam; SACET, Chirala; RISE, Ongole; SITS, Khammam; RGM CET, Nandyal & KGR CET, Hyderabad – 14 Years [2002-2016]
- Professor in Mechanical Engg @ KLU since 02-09-2016

Energy Conservation in HVAC Systems

By

Dr. K. V. Narasimha Rao, Ph. D., F. I. E.

Member: ASHRAE, ISCA, ISHMT, ISHRAE, ISTE & SESI

**Professor, Dept of Mechanical Engg and
Associate Dean-Quality**

K L University, Green Fields, Vaddeswaram

2 June 2020



1

Professional Experience

- Teaching & Research – at Vasavi, Hyderabad; IISc, Bangalore & M S R I T, Bangalore – 2 Years
- Industry: Premier Radiators Private Limited, Coimbatore – 1 Year (1994-1995)
- Consultancy & Applied Research – Tata Energy Research Institute, SRC, Bangalore–7 Years [1995-2002]
- Academic & Administration: Sree Vidyanikethan Engineering College, Tirupati; RIT, Yanam; SACET, Chirala; RISE, Ongole; SITS, Khammam; RGM CET, Nandyal & KGR CET, Hyderabad – 14 Years [2002-2016]
- Professor in Mechanical Engg @ KLU since 02-09-2016

Journey to a thousand miles starts with a single step!

- From Old Testament (or is it an old Chinese proverb?)

4

Scope of the Webinar

➤ HVAC means: Heating, Ventilation and A/c.

➤ What is covered:

➤ Refrigeration & air-Conditioning Systems

➤ Cooling Towers & Pumps (time permitting)

What is NOT covered:

➤ Heating

➤ Ventilation

5




K V T Prasad

Refrigeration and Air-conditioning System

- Selection criteria
- Estimation of TR generation & Specific power consumption - Performance Index (kW/TR)
- Detailed study of Air Handling Units (AHUs) - TR utilisation, effectiveness, etc.
- Insulation aspects and distribution loss estimation
- Fine tuning of parameters in Building Management System (BMS).

6

Refrigeration systems account for about 5% electricity consumption in the industrial sector; Industry consumes about 41% of total Electricity in India. Refrigeration accounts for 50-60% of energy consumption in Hotels.



Relationship of the refrigeration and Air-conditioning fields

Thermal Environmental Conditions for Human Occupancy

ANSI/ASHRAE Standard 55-2013 gives the thermal comfort conditions as follows:

1. Operative temperature: 20 to 26°C (Summer/Winter)
2. Humidity: A dew point temperature to 2 to 17°C (Equivalent to 33 to 58% RH)
3. Average air velocity: 0.25 m/s (Max: 0.8-1.0 m/s)
4. The air should be clean and odour-free

Note: Clothing and individual metabolism rates do matter.

8

Energy efficiency Ratios

The cooling effect of refrigeration systems is measured in Tonnes of Refrigeration (TR)

$$\begin{aligned} 1 \text{ TR} &= 3023 \text{ kcal/hour} \\ &= 3.517 \text{ kW} \\ &= 12,000 \text{ BTU/hour (refrigeration} \\ &\quad \text{required to make 1 ton of ice in 24 hours)} \end{aligned}$$

The commonly used figures of merit for comparison of performance of refrigeration systems are:

- COP (coefficient of performance)
- EER (energy efficiency ratio)
- kW/TR (specific power consumption)

9

The performance of refrigeration cycle is usually described by the COP. It is defined as the ratio of amount of heat removed (output) divided by the required energy (input) to operate the cycle.

$$\text{COP} = \text{Useful Refrigeration effect/Net work input}$$

10

Most commonly used refrigeration systems:

- Vapour compression system (PI \sim 0.6-0.9 kW/TR)
- Vapour absorption system (Low grade energy I/p)

Types of compressors used in VCS:

- Reciprocating compressors (Very small to 120 TR)
- Screw compressors (about 150 TR - 750 TR)
- Centrifugal compressors (150 TR - very large size)
- Scroll compressors (up to 30 TR)

Note: Compressor is called the "Work horse/heart" of VCS.

13

Comparison of the absorption and vapour compressor systems

- The vapour absorption system can be operated on waste heat.
- In the absorption system, except for two small electrically operated pumps, there are no moving parts. Hence, the absorption system has no vibration and does not need heavy foundation as required in vapour compression system; Less maintenance
- For the absorption machine, the capacity control is stepless whereas the vapour compression system can be controlled in certain steps.

15

Measurements/Field testing

The parameters needed to be looked into are:

- Inside and outside design conditions
- Measured flows and capacities of all the equipment used in the system (Condensers & Evaporators)
- Comparison of the measured and design capacities
- Comparison of energy consumption with the design values
- Operating head and flow rates of pumps.

18

Water flow

The water flow in a piping system is measured by:

- Taking the pumping head at the discharge and then referring the pump characteristic curves or
- Measuring the flow with a portable non-intrusive ultrasonic flow meter (Expensive: US\$10,000)

Air Flow

This is calculated by measuring the velocity across a fixed opening having a definite area. The velocity is determined by either measuring the pressure drop across the opening with the help of a pilot tube and manometer OR hot-wire anemometer.

19

Temperature/humidity

Two types of temperatures, DBT (dry bulb) and WBT (wet bulb) are measured by:

- Sling psychrometer (Simple, yet useful)
- Electronic thermo-hygrometer (e. g. Testo, Germany)

Electrical parameters:

Electrical measurements are taken with the help of a portable/fixed power analyzer.

20

Cooling tower

The heat rejected at the condenser must match the heat rejected at the cooling tower. The equation for cooling tower is the same as that of the water-cooled condenser. For the cooling tower, the approach should also be evaluated.

The efficiency of cooling tower is defined as:

Range (Water inlet temp. - water outlet temp.) /

Range - Approach (Water inlet temp. - ambient wet bulb temp.)

Note: When "Approach" becomes zero, efficiency becomes 100%

23

Energy conservation opportunities

- ☞ Circulation pumps operation
- ☞ Heat exchangers performance (Cond. & Evap.)
- ☞ Thermal storage (Time-of-day tariff, if any)
- ☞ Cooling tower fan motors
- ☞ Installing variable speed drives at AHU fan motors
- ☞ Reducing minimum out-door air
- ☞ Unoccupied ventilation reduction
- ☞ Reducing the heat loads in conditioned spaces (site-specific)

24

Switching off Secondary Pump at 360 TR Chiller Unit

The present refrigeration system consists of a 360 TR machine running with primary and secondary pumps. Primary pump will pump chilled water from hot well to cold well through evaporator. Secondary pump is in operation to pump chilled water from cold well to air washer. The measured pressure drop across evaporator is 0.5 kg/cm^2 , hence primary pump is sufficient to pump chilled water from hot well to air washer through evaporator. Hot well will take care of chilled water flow fluctuation.

27

Design specific power consumption	: 0.90 kW/TR
Operating specific power consumption	: 1.58 kW/TR

Energy Savings:

Reduction in power consumption for present load (63 TR)	: 42.8 kW
Annual operating hours	: 8500
Annual energy savings	: 3.64 Lakh kWh
Value of savings @ Rs.3.50 per kWh	: Rs. 12.74 Lakh
Investment for cleaning 3 chillers	: Rs.6.0 Lakh
Simple Payback Period	: 0.5 year

26

Suitable mono-block pump for chilled water

Make	: Kirloskar Brothers Ltd.
Type	: KDS-830
Flow	: 13 lps
Head	: 28 m
Power	: 5.5 kW
Overall efficiency	: 65%

Energy Savings

Present power consumption of pumps (2&3)	: 15.5 kW
Two mono-block pumps power consumption	: 11.0 kW
Reduction in power consumption	: 4.5 kW
Annual energy savings @8500 per year	: 38,000 kWh
Annual cost savings @Rs.3.00 per kWh	: Rs.1.14 Lakh
Investment for 3 No. monoblock	: Rs.0.82 Lakh
Simple payback period	: 0.8 year

The total cooling water flow requirement for VAC and brine chiller can be met by running condenser water pump of VAC.

Energy Savings

Present power consumption of brine chiller pump	: 11.4 kW
Annual energy savings	: 0.91 Lakh kWh
Value of savings @ Rs.3.50 / kWh	: Rs.3.20 Lakh
Investment	: Marginal
Simple Payback Period	: Immediate

Reduction in Speed of AHU Fan

The AHU connected to dry powder area (Pharmaceutical Industry) is not utilised fully. Some of the areas connected under this AHU are closed.

Measured air flow rate	: 20736 m ³ /h
Measured power consumption	: 3.18 kW
Reducing the fan speed	: 25% (permanently)

Energy Savings

Reduction in power consumption	: 1.8 kW
Annual operating hours	: 2400
Annual power savings	: 4320 kWh
Annual cost savings	: Rs.0.15 Lakh
Investment for pulley	: Rs.0.03 Lakh
Simple Payback Period	: 3 months

Reduction in Speed of AHU Fan

The AHU connected to dry powder area (Pharmaceutical Industry) is not utilised fully. Some of the areas connected under this AHU are closed.

Measured air flow rate : 20736 m³/h
Measured power consumption: 3.18 kW
Reducing the fan speed : 25% (permanently)

Energy Savings

Reduction in power consumption : 1.8 kW
Annual operating hours : 2400
Annual power savings : 4320 kWh
Annual cost savings : Rs.0.15 Lakh
Investment for pulley : Rs.0.03 Lakh
Simple Payback Period : 3 months

34


Installing Separate Cooling Tower for Refrigeration Load

Cooling tower supplies water to meet the cooling water requirement of Phase - I plants. The design approach of cooling tower is 4°C.

- Process cooling water
- Refrigeration condenser cooling water

As the cooling water temperature for process and refrigeration have different requirements of temperature, segregation of them will save energy.

38



39

Installing new cooling tower for refrigeration load, one pump of 990 kW (present consumption) can be switched off. Due to new cooling tower with lower approach of 2°C, reduction in refrigeration power consumption can be achieved.

Energy Savings

No. of pumps in operation at CT : 6
Total supply cooling water flow : 35,000 m³/h
Each pump design flow, head : 5,500 m³/h, 50 m
Power consumption of one pump : 990 kW
Refrigeration condenser cooling water flow (excluding new DBN) : 6,600 m³/h

40

Pumping power required at proposed cooling tower

Cooling water flow rate : 6600 m³/h
Head required : 32 m (max.)
Efficiency of pump : 88%
Efficiency of motor : 95%
Expected power consumption : 688 kW
Reduction in pumping power consumption : 990-688 = 302 kW
Annual operating hours : 8700
Annual energy savings : 26.27 lakh kWh
Value of energy savings : Rs.65.69 lakh

Cost of implementation

New pumps (4 Nos.) : Rs.40 lakh
Cooling tower for 12000 TR : Rs.85 lakh
Simple payback period : 1.9 years

Note: In the above proposal reduction in power consumption of refrigeration power is not considered, which is nearly 120 kW (10 lakh kWh per annum, i. e. Rs. 26 lakh)

41

Cooling Towers

- Cooling Tower is the most important Off-site Utility – usually treated as an Orphan
- Analyses of operating range and approach [Range: Inlet temp. – Outlet temp. of water]
- Cooling tower optimization
- High efficiency (lightweight) aero foil fans
- Automatic temperature controller

42


Replacing present chilled water pumps with mono-block pumps at 60 TR chiller

Efficiency evaluation of present pumps

Parameters	Unit	Design	Pump # 2	Pump # 3
Flow rate	lps	11.36	13.5	8.5
Head	m	30	30	30
Power	kW	5.66	8.73	6.84
Pump efficiency	%	59	-	-
Motor efficiency	%	88	-	-
Overall efficiency	%	52	45.5	36.5

Variation in flow is due to parallel operation

30




Primary pump delivery pressure : 3.5 kg/cm^2
 Pressure drop across evaporator : 0.5 kg/cm^2
 Pressure at the nozzles of air washer : $2.8\text{-}3.0 \text{ kg/cm}^2$

Energy Savings

Power consumption of secondary pump : 27.6 kW
 Annual energy savings : 2.35 lakh kWh
 Annual cost savings : Rs.7.05 lakhs
 Investment required : Rs.1.5 lakhs
 Simple payback period : 3 months

29



Primary pump delivery pressure : 4.5 kg/cm^2
 After throttling pressure : 1.2 kg/cm^2
 Secondary pump delivery pressure : 3.5 kg/cm^2
 Pressure drop across evaporator : 0.5 kg/cm^2

28

Improving "TR" Generation of 110 TR Refrigeration System

The 110 TR refrigeration system is not performing as per design. Even by pumping rated flow rate of chilled water, difference in temperature across chiller and condenser is not achieved.

Comparative Analysis of 110 TR Operating Vs Design

Parameters	Unit	Design	Actual
Capacity	TR	110	63
Input power	kW	100	99.5
Chilled water flow	lpm	1287	1590
Condenser water flow	lpm	1477	2490
ΔT across chiller	$^{\circ}\text{C}$	4.3	2.0
ΔT across condenser	$^{\circ}\text{C}$	4.6	1.8

Effect of variation in evaporator temperature on compressor power consumption

Evaporator temp. ($^{\circ}\text{C}$)	Refrigeration capacity (tonnes)	Specific power consumption (kW/tonne)	Increase in kW/tonne)
5.0	67.58	0.81	-
0.0	56.07	0.94	16.0
-5.0	45.98	1.08	33.0
-10.0	37.20	1.25	54.0
-20.0	23.12	1.67	106.0

Condenser temperature at 40°C

Effect of variation in evaporator temperature on compressor power consumption

Evaporator temp. (°C)	Refrigeration capacity (tonnes)	Specific power consumption (kW/tonne)	Increase in kW/tonne
5.0	67.58	0.81	-
0.0	56.07	0.94	16.0
-5.0	45.98	1.08	33.0
-10.0	37.20	1.25	54.0
-20.0	23.12	1.67	106.0

Condenser temperature at 40°C

17

Effect of variation in condenser temperature on compressor power consumption

Condensing temperature	Refrigeration capacity (tonnes)	Specific power consumption	Increase in kW/tonne (%)
26.7	31.5	1.17	-
35.0	21.4	1.27	8.5
40.0	20.0	1.41	20.5

Evaporator temperature at -10°C

16

ISHRAE

Thank you for attending the webinar!

If you would like to take ISHRAE Membership, please visit, www.ishrae.in

&

Please send your suggestions to us at ishraehc@gmail.com

Follow ISHRAE Deccan & Vijayawada Chapters on Facebook!

Slide 5 of 5 | English (India) | 12:41 | 02-06-2020